

Yusko-Kotimko, Tiffany (EGLE) <YuskoKotimkoT@michigan.gov>

Mon, Jan 6, 2020 at 2:48 PM

To: Scott Wood <scottwoodj@gmail.com>

Cc: Scott Wood <franklinknollshoa@gmail.com>

Hi Scott,

Regarding the sprinklers, I looked at the numbers on paper for water demand and I do have some concerns about the ability to support the demand of the sprinklers with the current system and operation. If your residents are serious about wanting this, I would recommend getting an engineering firm to review the hydraulics, storage, and various demands scenarios (including providing water to Briarcliff) and having them provide recommendations for system modifications. If you were to do this, you should discuss with the engineer what hydraulic modeling exercises would be most beneficial.

Let me know if you need another copy of the previous letter we sent to the HOA about this same topic several years back.

Please contact me if you have any questions.

Regards,

Tiffany

Tiffany Yusko-Kotimko

EGLE Drinking Water and Environmental Health Division | Warren District Office | 586-817-9120